



Ref. Certif. No.

CN13985

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST
CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE)
CB SCHEME

SYSTEME CEI D'ACCEPTATION MUTUELLE DE
CERTIFICATS D'ESSAIS DES EQUIPEMENTS
ELECTRIQUES (IECEE) METHODE OC

CB TEST CERTIFICATE

Product
Produit

Low-voltage fuses(Fuses with fuse-links with blade contacts)

Name and address of the applicant
Nom et adresse du demandeur

ZHEJIANG MINGRONG ELECTRICAL PROTECTION CO.,LTD
Wei llth Road,Economic Developing Zone,Yueqing Zhejiang Cchina

Name and address of the manufacturer
Nom et adresse du fabricant

ZHEJIANG MINGRONG ELECTRICAL PROTECTION CO.,LTD
Wei llth Road,Economic Developing Zone,Yueqing Zhejiang Cchina

Name and address of the factory
Nome et adresse de l'usine

ZHEJIANG MINGRONG ELECTRICAL PROTECTION CO.,LTD
Wei llth Road,Economic Developing Zone,Yueqing Zhejiang Cchina

Note: When more than one factory, please report on page 2
Note: Lorsqu'ily plus d'une usinem, veuillez utiliser la 2^{eme} page

Ratings and principal characteristics
Valeurs nominales et caractéristiques principales

Un:AC500V/690V; In:690V:4A, 6A, 10A, 16A, 20A, 25A, 32
A, 40A, 50A, 63A, 80A, 100A;500V:4A, 6A, 10A, 16A, 20
A, 25A, 32A, 40A, 50A, 63A, 80A, 100A, 125A, 160A;Rated
breaking capacity:500V/100kA,690V/50kA;Breaking range and utilizatio
n category:gG,fuse-holder:Un:AC690V,In:160A
MRO

Trademark (if any)
Marque de fabrique (si elle existe)

Model / Type Ref.
Ref. De type

RT16-00(NT00)

Additional information (if necessary may also be reported
on page 2)
Les informations complémentaires (si nécessaire, peuvent être
indiqués sur la 2^{eme} page)

PUBLICATION

EDITION

A sample of the product was tested and found
to be in conformity with
Un échantillon de ce produit a été essayé et a été
considéré conforme à la

IEC60269-2-1:2004(see also IEC60269-1:1998)

As shown in the Test Report Ref. No. which forms part
of this Certificate
Comme indiqué dans le Rapport d'essais numéro de
référence qui constitre partie de ce Certificat

C009-CB2009CQC-019342

This CB Test Certificate is issued by the National Certification Body
Ce Certificat d'essai OC est établi par l'Organisme National de Certification



CHINA QUALITY CERTIFICATION CENTRE

Date: 2009-05-22

Signature:

Wang Kejiao